

水 質 檢 查 結 果 一 覽 表

依 頼 者 直方市 上下水道・環境部 水道施設課

検 査 期 間 令和8年4月 ～ 令和8年8月

尾崎浄水場 尾崎貯水池 (6/001000002)

公益財団法人 北九州生活科学センター

TEL : 093-881-8282 FAX : 093-881-8333

コード	検 査 項 目	単 位	水質基準	検 査 結 果												最高値	最低値	平均値	水質基準超過数			
				尾崎浄水場 尾崎貯水池	尾崎浄水場 尾崎貯水池																	
				R8. 5. 14	R8. 8. 6																	
	天候（前日/当日）	-	--	晴/晴	晴/晴																	
	気 温	℃	--	21. 0	32. 0										32. 0	21. 0	26. 5					
	水 温	℃	--	21. 0	30. 5										30. 5	21. 0	25. 8					
	残留塩素	mg/L	--																			
1001	一般細菌	CFU/mL	100 以下		2000										2000	2000	2000	0	0	1		
1002	大腸菌	-	検出されないこと	検出	検出																	
1003	カドミウム及びその化合物	mg/L	0. 003 以下		0. 0003未満										0	0	0	0	0	0		
1004	水銀及びその化合物	mg/L	0. 0005 以下		0. 00005未満										0	0	0	0	0	0		
1005	セレン及びその化合物	mg/L	0. 01 以下		0. 001未満										0	0	0	0	0	0		
1006	鉛及びその化合物	mg/L	0. 01 以下		0. 001未満										0	0	0	0	0	0		
1007	ヒ素及びその化合物	mg/L	0. 01 以下		0. 001未満										0	0	0	0	0	0		
1008	六価クロム化合物	mg/L	0. 02 以下		0. 002未満										0	0	0	0	0	0		
1009	亜硝酸態窒素	mg/L	0. 04 以下		0. 027										0. 027	0. 027	0. 027	1	0	0		
1010	シアン化物イオン及び塩化シアン	mg/L	0. 01 以下		0. 001未満										0	0	0	0	0	0		
1011	硝酸態窒素及び亜硝酸態窒素	mg/L	10 以下		0. 4										0. 4	0. 4	0. 4	0	0	0		
1012	フッ素及びその化合物	mg/L	0. 8 以下		0. 10										0. 10	0. 10	0. 10	0	0	0		
1013	ホウ素及びその化合物	mg/L	1. 0 以下		0. 04										0. 04	0. 04	0. 04	0	0	0		
1014	四塩化炭素	mg/L	0. 002 以下		0. 0002未満										0	0	0	0	0	0		
1015	1, 4-ジオキサン	mg/L	0. 05 以下		0. 005未満										0	0	0	0	0	0		
1016	シス-1, 2-ジクロロエチン及びトランス-1, 2-ジクロロエチン	mg/L	0. 04 以下		0. 004未満										0	0	0	0	0	0		
1017	ジクロロメタン	mg/L	0. 02 以下		0. 002未満										0	0	0	0	0	0		
1018	テトラクロロエチレン	mg/L	0. 01 以下		0. 001未満										0	0	0	0	0	0		
1019	トリクロロエチレン	mg/L	0. 01 以下		0. 001未満										0	0	0	0	0	0		
1429	PFOS及びPFOA	mg/L	0. 00005 以下		0. 000005未満										0	0	0	0	0	0		
1020	ベンゼン	mg/L	0. 01 以下		0. 001未満										0	0	0	0	0	0		
1032	亜鉛及びその化合物	mg/L	1. 0 以下		0. 01未満										0	0	0	0	0	0		
1033	アルミニウム及びその化合物	mg/L	0. 2 以下		0. 13										0. 13	0. 13	0. 13	1	0	0		
1034	鉄及びその化合物	mg/L	0. 3 以下		0. 08										0. 08	0. 08	0. 08	1	0	0		
1035	銅及びその化合物	mg/L	1. 0 以下		0. 01未満										0	0	0	0	0	0		
1036	ナトリウム及びその化合物	mg/L	200 以下		22										22	22	22	0	0	0		
1037	マンガン及びその化合物	mg/L	0. 05 以下		0. 063										0. 063	0. 063	0. 063	0	0	1		
1038	塩化物イオン	mg/L	200 以下		11. 1										11. 1	11. 1	11. 1	0	0	0		
1039	カルシウム、マグネシウム等(硬度)	mg/L	300 以下		96										96	96	96	1	0	0		
1040	蒸発残留物	mg/L	500 以下		177										177	177	177	1	0	0		
1041	陰イオン界面活性剤	mg/L	0. 2 以下		0. 02未満										0	0	0	0	0	0		
1042	ジェオスミン	mg/L	0. 00001 以下		0. 000002										0. 000002	0. 000002	0. 000002	0	0	0		
1043	2-メチルイソボルネオール	mg/L	0. 00001 以下		0. 000014										0. 000014	0. 000014	0. 000014	0	0	1		
1044	非イオン界面活性剤	mg/L	0. 02 以下		0. 005未満										0	0	0	0	0	0		
1045	フェノール類	mg/L	0. 005 以下		0. 0005未満										0	0	0	0	0	0		
1046	有機物(全有機炭素(TOC)の量)	mg/L	3 以下		2. 1										2. 1	2. 1	2. 1	1	0	0		
1047	p H値	-	5. 8～8. 6		7. 8										7. 8	7. 8	7. 8					
1048	味	-	異常でないこと		-																	
1049	臭気	-	異常でないこと		藻臭																	
1050	色度	度	5 以下		8										8. 0	8. 0	8. 0	0	0	1		
1051	濁度	度	2 以下		4. 6										4. 6	4. 6	4. 6	0	0	1		
1073	嫌気性芽胞菌	CFU/100mL		6											6	6	6					
1078	クリプトスポリジウム	個/10L		0											0	0	0					
1079	ジアルジア	個/10L		0											0	0	0					
1501	PFOS	mg/L	-	0. 000005未満											0	0	0					
1502	PFOA	mg/L	-	0. 000005未満											0	0	0					